

EYEWASH/SOWER INSPECTION CHECKLIST

*****ANY "NO" ANSWERS MUST INCLUDE COMMENTS*****

Name of Inspected Property: _____	
Inspector Name: _____	Date: _____
Device Location: _____	Tag #: _____

Component	YES	NO	N/A	Comments
Eyewash/Shower unit located within 10 seconds (approximately 55 feet) of hazard and on the same level as hazard * In areas where strong acids or caustics are being handled, unit should be located adjacent to the hazard				
Unit has sufficient lighting and location identified with a highly visible sign				
Unobstructed path and access to the unit				
Hands-free water valve activates in 1 second or less and remains open until manually closed				
Water temperature is tepid (60-100°F)				
EYEWASH				
Heads are 33-53 inches above the floor				
Head must be positioned no closer than 6 inches from the wall or nearest obstruction				
Valve actuator is easy to locate and readily accessible				
Heads are protected from airborne contaminants				
Controlled, low velocity flow rinses both eyes simultaneously and is not injurious to user				
Water supply is sufficient to provide at least 0.4 gallons of water per minute for 15 minutes				
SHOWER				
Heads are 82-96 inches above the floor				
Center of the water pattern is at least 16 inches from any obstruction				
Valve actuator is easy to locate and readily accessible, no more than 69 inches above the floor				
At 60 inches above the floor, the water pattern is at least 20 inches in diameter				
Water supply is sufficient to provide at least 20 gallons of water per minute for 15 minutes				